



Split Duct – Frequently Asked Questions

I see from the Internet that there, apparently, is no split, sweep elbows greater than 4". How am I to use this product without the use of vertical and horizontal split, sweep elbows? What should I do?

Carlton's processes only can handle a maximum of a 4" split duct sweep. 5" and 6" were never made. In addition, we have not had the demand for the product to justify the cost on the new tooling.

We do have 5" and 6" split duct in straight lengths for repairs. Unfortunately, the cable or conductors will have to be pulled to replace the damage PVC conduit.

Do you have any UL listings for the Carlton Split Duct?

Split-Duct does not have a UL Listing. It is a product usually sold to utilities for repair (utilities do not require UL Listing). It is also used for telecommunications where listing is not required. If the project requires the repair to be listed than the only thing acceptable is to remove the conductors and replace the broken section with new product.

I am looking for Carlton part #S530, a strap for Split-Duct. I was told by my distributor that this part has been discontinued and is no longer available. Is this true? If so, is there a replacement part for it?

You can use any type of strap or tie wrap for the Split-Duct that you want to, provided it doesn't damage the split-duct. It doesn't have to be the #S530, which may have been discontinued.

I had a customer looking for the tape for split duct. This item has been discontinued so they would like to know what type of tape to purchase and from whom.

25701 Science Park Drive
Cleveland, Ohio 44122
216-464-3400
1-800-3CARLON (322-7566)
www.carlon.com



Split Duct – Frequently Asked Questions

There used to be a sticky tape, S500 that Carlton offered awhile back to seal the joints, under Split Duct accessories, and then discontinued. The next best thing might be duct tape, available in any hardware or retail store.

I have a request for quote for a part number 68215. The material is called Loc Duct. Is it discontinued?

"LOC DUCT®" now is known as Split Duct. The part number 68215 is no longer valid. Use 49015SD-010.

What is the difference between this E948NS Duct Coupling and the Split Sleeve Couplings?

The E948NS is split on two sides, whereas the split couplings for Split duct are only split on one side.

25701 Science Park Drive
Cleveland, Ohio 44122
216-464-3400
1-800-3CARLON (322-7566)
www.carlon.com